

COMMONWEALTH OF KENTUCKY
BEFORE THE ENERGY REGULATORY COMMISSION

* * * * *

In the Matter of

APPLICATION OF MR. LARRY ALLEN,)	
HAZARD, KENTUCKY, TO DEVIATE)	
FROM COMMISSION REGULATION 807)	CASE NO. 7718
KAR 50:045 SECTION 6, SUBPART 6)	

O R D E R

On January 15, 1980, Mr. Larry Allen, Hazard, Kentucky, filed a letter with the Commission requesting authority to use plastic pipe in the construction of a service line from his place of business to a gas line of Kentucky West Virginia Gas Company.

The Commission decided to treat this letter as an application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 50:045 Section 6, Subpart 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various surface plowing and digging activities and recommended the granting of the requested authority.

The Commission, having considered the Application, all evidence of record and being fully advised, is of the opinion and finds:

1. That a hearing to consider the merits of the Application will not be necessary.
2. That Mr. Larry Allen should be granted permission to use plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and is buried with a minimum of 36 inches cover.
3. That the completed service line installation shall be inspected by Commission staff members prior to the filling of the ditch.

4. That Mr. Larry Allen shall notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. That Mr. Allen shall meet all other requirements of the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6 in his installations.

IT IS THEREFORE ORDERED that Mr. Larry Allen, Hazard, Kentucky, be and he hereby is granted authority to deviate from the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6, Subpart 6 and install plastic pipe of an approved type in his service line said pipe to be buried with a minimum of 36 inches cover.

IT IS FURTHER ORDERED that Mr. Larry Allen notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of Utility Engineering and Services of the Energy Regulatory Commission before service is rendered.

Done at Frankfort, Kentucky, this 19th day of February, 1980.

ENERGY REGULATORY COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Secretary